



Product Service

# Attestation of Conformity

No. D6 108819 0010 Rev. 00

**Holder of  
Attestation:****ALP POMPA TEKNOLOJILERI  
TICARET SANAYI A.S.**Dudullu OSB 2.Cadde No:14  
34775 Umraniye Istanbul  
TÜRKIYE**Product:  
Model(s):****Circulation pump  
ECP32-120F 220, ECP32-120F 220N****Parameters:**Rated voltage: 230V~  
Rated frequency: 50/60Hz  
Rated input power: 329W Max.  
Protection class: I  
Degree of protection: IP44  
Declared head: 12 m Max.  
Declared flow: 17 m<sup>3</sup>/h Max.  
Declared EEI: Less than 0.23Implementation Measure EC Regulation  
No 641/2009: 2009-07-22 amended by  
(EU) 622/2012:2012-07-11, (EU) 2016/2282: 2016-11-30,  
(EU) 2019/1781:2019-10-01  
Stage 2 (2015-08-01)**Brand Name:****ETNA****Tested  
according to:**PPP 11093E:2019  
EN 16297-1:2012  
EN 16297-2:2012  
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:**

871282304806-00

**Date,** 2023-11-20

( Lucy (Jianying) Lu )



Product Service

# Attestation of Conformity

No. D6 108819 0011 Rev. 00

**Holder of  
Attestation:**

**ALP POMPA TEKNOLOJILERI  
TICARET SANAYI A.S.**

Dudullu OSB 2.Cadde No:14  
34775 Umraniye Istanbul  
TÜRKIYE

**Product:  
Model(s):**

**Circulation pump  
ECP40-120F 250, ECP40-120F 250N**

**Parameters:**

Rated voltage: 230V~  
Rated frequency: 50/60Hz  
Rated input power: 463W Max.  
Protection class: I  
Degree of protection: IP44  
Declared head: 12m Max.  
Declared flow: 24 m<sup>3</sup>/h Max.  
Declared EEI: Less than 0.23

Implementation Measure EC Regulation  
No 641/2009: 2009-07-22 amended by  
(EU) 622/2012:2012-07-11, (EU) 2016/2282: 2016-11-30,  
(EU) 2019/1781:2019-10-01  
Stage 2 (2015-08-01)

**Brand Name:**

**ETNA**

**Tested  
according to:**

PPP 11093E:2019  
EN 16297-1:2012  
EN 16297-2:2012  
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:**

871282304807-00

**Date,** 2023-11-20

( Lucy (Jianying) Lu )



Product Service

# Attestation of Conformity

No. D6 108819 0012 Rev. 00

**Holder of  
Attestation:****ALP POMPA TEKNOLOJILERI  
TICARET SANAYI A.S.**Dudullu OSB 2.Cadde No:14  
34775 Umraniye Istanbul  
TÜRKIYE**Product:  
Model(s):****Circulation pump  
ECP40-150F 250, ECP40-150F 250N****Parameters:**

Rated voltage:	230V~
Rated frequency:	50/60Hz
Rated input power:	615W Max.
Protection class:	I
Degree of protection:	IP44
Declared head:	15m Max.
Declared flow:	26.2 m <sup>3</sup> /h Max.
Declared EEI:	Less than 0.23

Implementation Measure EC Regulation  
No 641/2009: 2009-07-22 amended by  
(EU) 622/2012:2012-07-11, (EU) 2016/2282: 2016-11-30,  
(EU) 2019/1781:2019-10-01  
Stage 2 (2015-08-01)**Brand Name:****ETNA****Tested  
according to:**PPP 11093E:2019  
EN 16297-1:2012  
EN 16297-2:2012  
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:**

871282304808-00

**Date,** 2023-11-20

( Lucy (Jianying) Lu )



Product Service

# Attestation of Conformity

No. D6 108819 0013 Rev. 00

**Holder of  
Attestation:****ALP POMPA TEKNOLOJILERI  
TICARET SANAYI A.S.**Dudullu OSB 2.Cadde No:14  
34775 Umraniye Istanbul  
TÜRKIYE**Product:  
Model(s):****Circulation pump  
ECP50-180F 280, ECP50-180F 280N****Parameters:**

Rated voltage:	230V~
Rated frequency:	50/60Hz
Rated input power:	769W Max.
Protection class:	I
Degree of protection:	IP44
Declared head:	18m Max.
Declared flow:	37.5 m <sup>3</sup> /h Max.
Declared EEI:	Less than 0.23

Implementation Measure EC Regulation  
No 641/2009: 2009-07-22 amended by  
(EU) 622/2012:2012-07-11, (EU) 2016/2282: 2016-11-30,  
(EU) 2019/1781:2019-10-01  
Stage 2 (2015-08-01)**Brand Name:****ETNA****Tested  
according to:**PPP 11093E:2019  
EN 16297-1:2012  
EN 16297-2:2012  
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:**

871282304809-00

**Date,** 2023-11-20

( Lucy (Jianying) Lu )



Product Service

# Attestation of Conformity

No. D6 108819 0014 Rev. 00

**Holder of  
Attestation:****ALP POMPA TEKNOLOJILERI  
TICARET SANAYI A.S.**Dudullu OSB 2.Cadde No:14  
34775 Umraniye Istanbul  
TÜRKİYE**Product:****Circulation pump****Model(s):****ECP65-150F 340, ECP65-150F 340N****Parameters:**

Rated voltage:	230V~
Rated frequency:	50/60Hz
Rated input power:	1263W Max.
Protection class:	I
Degree of protection:	IP44
Declared head:	15m Max.
Declared flow:	56 m <sup>3</sup> /h Max.
Declared EEL:	Less than 0.23

Implementation Measure EC Regulation  
No 641/2009: 2009-07-22 amended by  
(EU) 622/2012: 2012-07-11, (EU) 2016/2282: 2016-11-30,  
(EU) 2019/1781: 2019-10-01  
Stage 2 (2015-08-01)**Brand Name:****ETNA****Tested  
according to:**PPP 11093E:2019  
EN 16297-1:2012  
EN 16297-2:2012  
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:**

871282304810-00

**Date,**

2023-11-20

( Lucy (Jianying) Lu )